


Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information – for 97 Burwood Road, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information - 27-31 Belmore Street, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information –for 42-50 Railway Parade, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information for 34-46 George Street, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information for 127-133 Burwood Road, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

**Legionnaires' disease cluster in inner west Sydney
Follow-up information for 52-60 Railway Parade, Burwood**

Dear building /owner/occupier,

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,



Dr Leena Gupta
Director, Public Health

30 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information for 48-56 George Street, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Graham Burgess'.

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au

Population Health



Health
Sydney
Local Health District



Legionnaires' disease cluster in inner west Sydney Follow-up information –for 42-50 Railway Parade, Burwood

As part of the investigation into the recent cluster of Legionnaires' disease in inner west Sydney, Sydney Local Health District's Public Health Unit recently inspected the cooling tower(s) associated with a building which you own or occupy. Council's cooling tower register indicates you are the contact person so we are writing with further important information. During the inspection, water samples were collected for laboratory testing for Legionella. The samples collected at this building were negative for Legionella.

Whilst this is a negative result, it is important to emphasise that this reflects the quality of the cooling tower water at only a single point in time. It is important that correct monitoring, operation and regular maintenance of the tower continues.

All cooling towers should be maintained and operated in accordance with the manufacturer's instructions, as well as Australian Standard – AS3666 and the *NSW Public Health Act 2010* (www.legislation.nsw.gov.au/inforce/e20f1d11-6a0d-ec9a-fe79.../2010-127.pdf) and *Public Health Regulation 2012* (http://www.austlii.edu.au/au/legis/nsw/consol_reg/phr2012217/).

If you have any queries, please contact the Environmental Health team at Sydney Local Health District Public Health Unit on (02) 9515 9420 or Burwood Council on (02) 9911 9911.

Yours sincerely,

Graham Burgess
Acting Director, Public Health

27 May 2016

Public Health Unit

PO Box 374
CAMPERDOWN NSW 2050
Tel: 612 9515 9420 Fax: 612 9515 9441
Website: <http://www.slhd.nsw.gov.au/populationhealth/PHU.html>

Sydney Local Health District

ABN 17 520 269 052
Website: www.slhd.nsw.gov.au